





Appendix A: Site Survey For Proposed 305 Toxics Environmental Room

 <p>East Wall of 305 Lab including entry door. Northeast side of room</p> <p>East</p>	<p>Location and Size</p> <p>Recommended nominal dimension: <i>16' N-S x 8' E-W Environmental Room</i> <i>4' N-S x 4' E-W Airlock Room</i></p> <p>Tile Floor in environmental room footprint will be removed by EPA. Drop ceiling will be removed by EPA in area of environmental room footprint.</p>
 <p>East Wall of 305 Lab. Southeast side of room.</p> <p>East</p>	<p>Location and Size</p> <p>FM-200 fire suppression to be removed and reinstalled by EPA. Tile Floor in environmental room footprint will be removed by EPA. Drop ceiling will be removed by EPA in area of environmental room footprint. Existing countertop and cabinets will be removed by EPA.</p>

Appendix A: Site Survey For Proposed 305 Toxics Environmental Room

 <p>North Wall of 305 Lab. Northeast side of room.</p> <p>North</p>	<p>Location and Size</p> <p>Tile Floor in environmental room footprint will be removed by EPA.</p> <p>Drop ceiling will be removed by EPA in area of environmental room footprint.</p> <p>Airlock location and existing entry door.</p>
 <p>South Wall of 305 Lab. Southeast side of room.</p> <p>South</p>	<p>Location and Size</p> <p>Drop ceiling will be removed by EPA in area of environmental room footprint.</p> <p>Existing countertop, cabinets, and sink will be removed by EPA.</p>